

1. Univocal product-type identification code: **CUBE-AL BATH (complete range)**

2. Type, lot, series no. or any other element that enables the construction product to be identified pursuant to article 11, paragraph 4: **CUBE-AL BATH**

3. Intended use(s) of the construction product according to the relative harmonised technical specification, as stated by the manufacturer: **Heat emitting radiators designed for permanent installation in heating systems of residential buildings, fed from a remote source with hot water or steam at a temperature < 120 °C. (EN 442-1 December 2014, EN 442-2 December 2014)**

4. Name, registered trade name or registered trademark and address of the manufacturer pursuant to article 11, paragraph 5: **RIDEA S.r.l. - Via E. Ferrari, 1 - 62017 - Porto Recanati (MC) - ITALIA**
sede legale: Via Francesca 54/A - 24040 - Ciserano (BG) - ITALIA

5. If applicable, name and address of mandatory whose mandate includes the assignments as per article 12, paragraph 2: **N.A.**

6. System(s) for the assessment and verification of constancy of performance of the construction product, as per annex V: **system 3.**

7. In a declaration of performance concerning a construction product that comes under the scope of a harmonised standard:
Notified Testing Laboratory: Politecnico di Milano – Energy Department (Notified body number: 1695)
(name and identification number of notified body, if applicable)
has performed **type tests (standard UNI EN 442-1)** according to system **3.**
(description of third party assignments as per annex V)
and has issued:
 - **Determination of the thermal output of a heating body (Test report ENE/MRT.ITPL-14004 of 27/02/14)**
 - **Pressure tightness tests (Test report ENE/MRT.ITPL.14004 of 27/02/14)**(constancy of performance certificate, plant production control conformity certificate, test/design reports – as applicable)
.....
(name and identification number of organisation notified, if applicable)
.....
(description of third party assignments as per annex V)
and has issued:
.....
(constancy of performance certificate, plant production control conformity certificate, test/design reports – as applicable)

8. In a declaration of performance concerning a construction product for which a European technical assessment has been released:

N.A.

(name and identification number of technical assessment body, if applicable)

has released

.....
(reference number of European technical assessment)

based on

.....
(reference number of European assessment document)

performed according to system

(description of third party assignments as per annex V)

and has issued

.....
(constancy of performance certificate, plant production control conformity certificate, test/design reports – as applicable)

9. Performance declared

Notes to table:

1. Column 1 contains the list of the basic properties as defined in the harmonised technical specifications for the use(s) specified in § 3 above;
2. For each property listed in column 1 and conforming to the requirements as per article 6, this column gives the performance declared, expressed in terms of level, class, or through a description, in relation to the corresponding basic properties. If no performance has been declared, the column shows “NPD” (No Performance Determined);
3. For each basic property listed in column 1, column 3 gives:
 - a. A reference, with relative date, to the corresponding harmonised standard, and, if applicable, the reference number of the specific technical documentation, or that of the appropriate technical documentation used;
 - or
 - b. A reference, with relative date, to the corresponding European assessment document, if available, and the reference number of the European technical assessment used;

Basic properties (see note 1)	Performance (see note 2)	Harmonised technical spec. (see note 3)
Reaction to fire	A1	Tests on organic part of any paint or surface treatment substance to verify whether it is <1 % by mass. (Clause 5.2, standard EN 442-1:2014)
Release of hazardous substances	None	Clause 5.3, standard EN 442-1:2014
Surface temperature	120° C maximum and corresponding to water supply temperature	EN 442-1:2014
Maximum operating pressure	16 bar	EN 442-1:2004
Pressure tightness (leak test)	20,8 bar	Clause 5.4, standard EN 442-1:2014
Pressure tightness (resistance test)	27 bar	Clause 5.6, standard EN 442-1:2014
Rated thermal output ΔT 50 K	See Table 1	Clause 5.8, standard EN 442-1:2014
Rated thermal output ΔT 30 K	See Table 1	Clause 5.8, standard EN 442-1:2014
Thermal power in different operating conditions (Characteristic equation)	$\bullet = K_m \times \Delta T^n$	Clause 5.8, standard EN 442-1:2014
Coefficient K_m	See Table 1	Clause 5.8, standard EN 442-1:2014
Coefficient n	See Table 1	Clause 5.8, standard EN 442-1:2014
Durability (impact resistance lightweight)	Level 0	Clause 5.9, standard EN 442-1:2014
Durability (corrosion test)	No corrosions after 100 h of humidity	Clause 5.9, standard EN 442-1:2014

If a specific technical document has been used, pursuant to art. 37 or art. 38, the requirements met by the product:

.....

.....

10. The performance of the product as per §§ 1 & 2 above conforms to the performance declared as per § 9.

TABLE 1 (tecnica data)

Modell	Rated thermal output ΔT 50 K	Rated thermal output ΔT 30 K	Coefficient Km	Coefficient n
Cube-Al Bath (80/40)	296,0 Watt	158,8 Watt	2,510	1,219
Cube-Al Bath (80/45)	318,0 Watt	170,6 Watt	2,689	1,219
Cube-Al Bath (80/50)	340,0 Watt	182,3 Watt	2,868	1,220
Cube-Al Bath (80/55)	362,0 Watt	194,0 Watt	3,045	1,221
Cube-Al Bath (80/60)	384,0 Watt	205,8 Watt	3,222	1,221
Cube-Al Bath (120/40)	432,0 Watt	231,4 Watt	3,619	1,222
Cube-Al Bath (120/45)	464,0 Watt	248,6 Watt	3,899	1,221
Cube-Al Bath (120/50)	495,0 Watt	265,4 Watt	4,180	1,220
Cube-Al Bath (120/55)	527,0 Watt	282,7 Watt	4,464	1,219
Cube-Al Bath (120/60)	558,0 Watt	299,5 Watt	4,750	1,218
Cube-Al Bath (150/40)	541,0 Watt	289,0 Watt	4,704	1,226
Cube-Al Bath (150/45)	581,0 Watt	311,0 Watt	4,853	1,223
Cube-Al Bath (150/50)	622,0 Watt	333,8 Watt	5,281	1,218
Cube-Al Bath (150/55)	662,0 Watt	356,0 Watt	5,723	1,214
Cube-Al Bath (150/60)	702,0 Watt	378,5 Watt	6,178	1,209
Cube-Al Bath (180/40)	651,0 Watt	346,9 Watt	5,238	1,232
Cube-Al Bath (180/45)	702,0 Watt	375,6 Watt	5,822	1,224
Cube-Al Bath (180/50)	753,0 Watt	404,3 Watt	6,438	1,217
Cube-Al Bath (180/55)	804,0 Watt	433,5 Watt	7,087	1,209
Cube-Al Bath (180/60)	854,0 Watt	462,3 Watt	7,770	1,201

This declaration of performance is released under the sole responsibility of the manufacturer as per § 4 above.

Signed in the name and on behalf of:

CHIARA FOGLIENI

Managing Director
(name and functions)



Ridea SRL
heating design
FECS

Sede Legale: Via Francesca 547/A - 24041 CISERANO (BG)
Unità prod.: Via Enzo Ferrari 1 - 62017 PORTO RECANATI (MC)
Tel/Fax 0717506170 - REA BG 463592 - info@ridea.it
P.I. 01692990433 - Cap. Soc. i.v. 100.000,00

(signature)

Porto Recanati (MC – Italy) 13/12/2021
(place and date of issue)